

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7770-1209:147 Page 1 of 1

CATEGORY: Valves/Switches

LISTEE: System Sensor, 3825 Ohio Ave., St. Charles IL 60174
Contact: *Trish Linhart (630) 377-6674 Fax (630) 377-7245

DESIGN: Models EPS10-1, EPS10-2, EPS40-1, EPS40-2, EPS120-1 and EPS120-2 pressure switches and Model 546-8000 cover tamper switch. Suitable for use in dry or wet pipe systems. Suitable for indoor or outdoor use. Refer to listee's data sheet for detailed product description and operational considerations.

RATING:

EPS10:	4-20 psi
EPS40:	10-100 psi
EPS120:	10-200 psi

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating, pressure range and UL label.

APPROVAL: Listed as pressure switches for use in dry or wet pipe fire sprinkler systems.

*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 16, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager